



TOWN OF PLATTSBURGH
WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198

Michael S. Cashman
Supervisor

Meg E. LeFevre
Deputy Supervisor

January 23, 2020

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department

RE: **Water & Wastewater December Report**

- Collected all required monthly samples.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Reviews of the monthly Planning Board Meeting regarding upcoming projects.
- 164 daily job orders completed and 128 utility locates for Dig Safely NY, including 15 Emergency Locates.
- Reviewed monthly Safety Sheets.
- There were 3 afterhours callouts. Shut off water in Champlain Park and 2 emergency undergrounds, one in Cadyville and another on Cumberland Head.
- Cleaned the bar screen and vac'd out the manhole at the Clinton County Sheriff Department 5 times.
- Installed a replacement heater at Cumberland Corners Tower.
- One supervisor attended ongoing training at the Chamber of Commerce.
- Installed a 1" commercial water service at the new development on Banker Road.
- Made repairs to a leak on the water main of Rugar Street.
- Cleaned manholes in the Tom Miller area.
- Onsite annual inspection of CWWTP with NYSDEC.
- Rebuild kit at the 8" PRV in Cadyville.
- Two residential service shut offs repaired, on Route 9 S and the second on Military Turnpike.
- Cleaning and maintenance at the CWWTP, also pulled and cleaned the number two pump 3 times.
- Filling the most recently coated tank on Kimberley for sampling.
- Jetting for the Highway Department on Cumberland Head.
- There was a water break on PARC when the contractor working on the housing development dug through an existing water service. We isolated the area and back fed Kinney Drug and the DFCU with assistance from the City of Plattsburgh DPW. A Precautionary Sample was collected.
- The same contractor need the main shut down again, this time for scheduled work connecting to the water main. We took this opportunity to make repairs to a MLV in this pressure zone. Again we back fed from the City of Plattsburgh, this time

however a Boil Water Order was issued and consecutive samples collected. The order was lifted.

- Pulled and cleaned pump at Sorrell Lift Station. We also replaced an impeller in efforts to up the gpm of this pump, it did not work.
- Hydrant repairs on Cumberland Head.
- Tighten the packing at Connecticut Lift Station.
- Plowing, shoveling and sanding at plants and hydrants throughout the district.