



TOWN OF PLATTSBURGH
WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198

Michael S. Cashman
Supervisor

Meg E. LeFevre
Deputy Supervisor

July 7, 2020

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department

RE: **Water & Wastewater June Report**

- Collected all required monthly samples, including Asbestos sampling.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Reviews of the monthly Planning Board Meeting regarding upcoming projects.
- 132 daily job orders. 202 locates for DSNY including 5 Emergency.
- There were 6 after hours call outs.
 - 1-False alarm for an alarm light at Tom Miller Road Lift Station.
 - 2-After hours sewer lateral replacement inspection in Champlain Park.
 - 3-Low wet well, and low system pressure issues related to Champlain Park Tower draining, and production versus consumption issues.
 - 4-Over temperature alarm at Sorrell Lift Station.
 - 5-Low wet well at Singing Sands Pump Station.
 - 6-Responded to a call for a water leak on Route 3 that was a storm drain/roof drain issue.
- Work with the contractor on the Harney Bridge Replacement Project.
- Troubleshooting generator issues at Cliff Haven Main Station.
- 8 residential shut off repairs.
- There was a water main break on Trade Road. The affected area was isolated and the north end was maintained from the Champlain Park Water Tower. Repairs were made to the hydrant valve that had failed and the water was turned back on in about 2 hours. A Boil Water Order was issued, consecutive samples were collected, and the order was lifted.
- Purchased and installed a hot water tank at CWWTP.
- Drained Champlain Park Water Tower for repainting the interior.
- Check static pressure on Baker Road for future development.
- Clean the clear well at GPWTP.
- MLV box repair on Superior Drive.
- Work with NYSDOT for the resurfacing of Route 22B Project. 5 MLV boxes were cleaned, repaired and raised in the Schuyler Falls Water District.
- Replaced the coolant in GPWTP generator.
- Hydrant repair on Route 374.
- Replaced the chemical injection lines at GPWTP.
- Pull and clean pump at Sorrell Lift Station.
- Investigate sewer issues for Saranac Power Partners.

- Clean I-87 Lift Station.
- Picked up repaired fleet vehicle from Bailey Ford.
- Restoration for previous projects.
- In house and town wide vehicle and equipment maintenance and repairs.