



**TOWN OF PLATTSBURGH  
WATER AND WASTEWATER DEPARTMENT**

151 BANKER ROAD  
PLATTSBURGH, NEW YORK 12901-7307  
(518) 562-6890  
FAX # (518) 563-8198

*Michael S. Cashman  
Supervisor*

*Meg E. Bobbin  
Deputy Supervisor*

May 12, 2021

To: Honorable Michael S. Cashman  
Members of the Town Board

From: Water & Wastewater Department

**RE: Water & Wastewater April Report**

- Collected all required monthly samples, including PFOA/Diox sampling for Greater Plattsburgh, and Cadyville
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Reviews of the monthly Planning Board Meeting regarding upcoming projects.
- 146 daily job orders. 176 locates for DSNY including 5 Emergency.
- There was one scheduled call out for the collection of fire flow data on Plaza Blvd. This was set for this time due to the potential of interfering with the dialysis unit at CVPH.
- There were 4 afterhours callouts. Two were for low clear well alarms at GPWTP. These were caused due to power interruptions that tripped Well 7 out. One was for a hydrant/MVA on Cumberland Head. The fourth was a water main break on PARC (mentioned in the next item).
- The contractor installing the new water main on PARC had 4 water main emergency incidents requiring shut downs. There were two Boil Water Orders issued with consecutive sampling and lift order distribution. The other two breaks were repaired in a timely fashion and CCDH was satisfied with collecting a single "precautionary sample" for each incident.
- Pull and clean number 2 pump at Banker Road Lift Station.
- Pulled and cleaned CWWTP pumps, also refastened the pump rails, straightened the gate, and installed a new latch on the door.
- Hydrant repair Tom Miller Road.
- Check MLV box accessibility and valve operations for Route 3 commercial project.
- Clean UV system at CWWTP.
- Pull and clean pumps Banker Road Lift Station.
- Pull and clean pump CWWTP and replace O ring.
- Dead end hydrant flushing.
- Clean manholes CWWTP.
- Pull and clean pumps Banker Road Lift Station.

- Pump out PRV vaults.
- Repaired break to service line on Route 22B in Schuyler Falls. No Boil Water Order required, repairs made under pressure.
- Installed a new electrical service line from panel to new disconnect and tied in pump at Sorrell Pump Station.
- Pull and clean both pumps at Tom Miller Road Lift Station.
- Meter change outs in Treadwell Mill's area. Went door to door to unresponsive customers to gain access, and left door hangers for the customers that weren't home.
- Check on delivery power issues at Champlain Park Water Tower.
- Discussions with representative for fleet vehicle management/maintenance program.
- Televiser section of sewer main in Bluff Point looking for a dead end manhole and there was none.
- Cut trees and brush at Sorrell Lift Station.
- Cleaned out a manhole at PARC.
- Hydrant repair on Cumberland Head.
- Began mowing for the season.
- Repaired hydrant valve box in Wallace Hill.
- Located a residential shut off in Bluff Point that we did not know existed previously (it was under the asphalt in the road).
- Restorations for previous projects including; Wood Street, Military Turnpike, Lynn Avenue, and Algonquin Park Road.
- Prepped sidewalks for restoration on Route 3 and Route 22B.
- Departmental and town wide vehicle and equipment maintenance and repairs.