



TOWN OF PLATTSBURGH
WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198

Michael S. Cashman
Supervisor

Meg E. Bobbin
Deputy Supervisor

August 4, 2021

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department

RE: **Water & Wastewater July Report**

- Collected all required monthly samples, including DBP for Greater Plattsburgh and Cadyville, and PFOA/Diox for Wells 6&7 at GPWTP and Well 2 in Cadyville.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Reviews of the monthly Planning Board Meeting regarding upcoming projects.
- 121 daily job orders. 152 locates for DSNY including 8 Emergency.
- There were 4 after hours call outs. There was a broken baseplate in Champlain Park. A call for water in the ditch on Cumberland Head which was due to the Champlain Park Storage Tank overfilling. We were called to Village Drive which was a broken baseplate in the meter pit. Called out by a resident in Cliff Haven for a hydrant leaking.
- 5 operators received their Asbestos Physicals and Respirator Fit Tests.
- Replaced the operating nut on the interconnecting main line valve located on Monroe Way.
- Inspecting the installation, pressure testing, disinfecting, and sampling of the water main extension project on Cumberland Head.
- There was a water main break on Kensington Road on Cumberland Head. Due to storage tank issues and the number of valves required to isolate the break most of Cumberland Head had an interruption of service. For these reasons there was a large BWO implemented for this area. The repairs were made and the system was reenergized. Sampling was done the following week for added precautionary reasons and the BWO was lifted.
- Overflowing of Champlain Park Water Tower to improve water quality.
- Clean grit pad Champlain Park Lift Station.
- Televis sewer main in Wallace Hill for resident issues.
- Televis storm drain for Highway Department on Independence Drive.
- Worked with the contractor installing the new water main and services on PARC.

- Firehouse Lane PRV not responding properly. We isolated it during the day and supplied Cumberland Head from the tank, then reactivated it at the end of the day to prevent overflowing and potential residential complaints.
- Dried sludge (14 tons) hauled from Champlain Park drying bed to the Franklin County Landfill.
- Cadyville PRV leaking by. We set up a hydrant relief valve temporarily to prevent the system from over pressurizing. Installed a rebuild kit in the PRV and it continued to leak by. We determined the saw tooth seat in the valve was worn and pitted allowing the over pressurizing. We sent an operator the following day to get a replacement and more rebuild kits and another hydrant relief valve. We installed the new seat and the system is back at its normal operating range.
- Began filling Bluff Point Water Tower. This was a three day process, shutting the tank down at night to prevent the tank from equalizing and potentially going back into the system. Once this was done we met with the contractor to assist with the sampling.
- Rebuilt Firehouse Lane PRV. There were several days of adjusting the valves to get it back to its normal operating range.
- Worked with the consulting engineer at Quarry Road, and Eddie Drive in an attempt to try and determine the proper settings for the new PRV on Quarry Road. We also assisted them on Macey Lane for a project with the Town of Schuyler Falls.
- Cleaned the digester at CWWTP.
- Made repairs to fire hydrant located at Bluff Point Tower.
- Shut off repaired on Flanagan Drive.
- There were issues with the John Deere Backhoe not running. Nortrax in Williston VT was contacted for troubleshooting and to make the repairs.
- Continued efforts on the Fleet System Management Program.
- Investigated an ongoing leak on Montana Drive. It was determined this was ground water/drainage issue. We capped the line in an attempt to prevent this from discharging anymore.
- Installed a same side 1" residential water service on Sunrise Drive in Beekmantown.
- Concrete restoration in Cliff Haven.
- Asphalt restoration on Route 3, Brookside Ave, and Route 22B in Schuyler Falls.
- Flushed the dead end line on Fatima St. in Woods Mills.
- Delivered the CAT generator to Bluff Point Main Station for the contractor to use for temporary power supply.
- NYS Inspection Audit.
- Pulled the number 2 pump at CWWTP and sent out for repairs.
- Placed Bluff Point Water Tower back in service and returned CC OES their hydrant relief valve that was in service on Champlain Drive in Cliff Haven.
- Responded to calls for MVA with hydrants on Cumberland Head, Military Turnpike, and Route 22B. All the hydrants have been repaired and are back in service.
- In house and town wide vehicle and equipment maintenance and repairs.
- Seasonal beautification.