



TOWN OF PLATTSBURGH
WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198

Michael S. Cashman
Supervisor

Charles Kostyk
Deputy Supervisor

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department

RE: Water & Wastewater June Report

- Collected all required monthly samples, including Lead & copper Samples for Cliff Haven, Bluff Point, and Schuyler Falls, Morrisonville Water District.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Review of the monthly Planning Board Meeting regarding upcoming projects.
- There were 117 daily job orders, and 162 locates for DSNY including 12 Emergency.
- There were 4 afterhours callouts.
 1. We responded to a call from a residence on Sawyer Lane that they had no water. We determined that the Verizon Contractor had damaged the service line to the home. We were able to temporarily supply the home with water from the neighbor's house.
 2. There was an alarm at Singing Sands Lift Station on Wood Cliff Drive, the pump was pulled and cleaned.
 3. We received a call from a homeowner on Ladue St in Schuyler Falls that they had a leak on the service line, we shut the water off..
 4. We were paged out by a homeowner on Cumberland Head who had a leak in their basement. We replaced the entire meter assembly.
- Replaced bolts on 3 main line valves on Nomad Drive.
- Witnessed pump station start up at I-87.
- Delivered a Myers Sewage Pump and the CentiPro electric motor from Well 1 to Emerick Associates for evaluation, and picked up the FLYGT Pump for Sorrell Lift Station.
- Pull and clean pumps at Tom Miller Lift Station.
- Cleaned the number two check valve at Sorrell Lift Station.
- Cleaned the manholes in Cadyville Sewer District.
- Cleaned the wet well at Sorrell Lift Station and installed the recently rebuilt FLYGT Pump.
- Repairs were made to service line that was damaged by Morrisonville Construction (working for Verizon) on Sawyer Lane. They were charged for time and materials.
- Installed a 2" water tap on Tom Miller Road for a residential/commercial project.

- Made repairs to a hydrant on Village Drive.
- Repaired a shut off on Irish Settlement Road.
- Repairs were made to a service line on NYS Route 22B in Schuyler Falls. A precautionary sample was collected.
- Troubleshooting pump flows at Sorrell Lift Station.
- Made repairs to a service line in Schuyler Falls.
- Fixed the conduit and wire for the heater at Akey Road Pump Station.
- All attended Conflict Resolution Training at Town of Plattsburgh.
- Hydrant repairs on Industrial Blvd.
- One operator completed online training course.
- Two shut off repairs on NYS Route 9N.
- Cleaned wet well at Flanagan Lift Station.
- Fire extinguisher testing.
- Pull and clean number one pump at Sorrell Lift Station.
- Replaced the plumbing inside Banker Road Lift Station.
- Ongoing efforts with City of Plattsburgh for their water main replacement project on PARC.
- Picked up a hydrant hit by NYS Police on NYS Route 9 made repairs and reinstalled.
- Sandblasting, primer and top coat hydrants on Tom Miller Road.
- In house and town wide vehicle equipment maintenance and repairs.
- Concrete, asphalt, and top soil restorations for previous projects.
- Seasonal beautification.