



HULBERT SUPPLY - PLATTSBURGH

390 NY-3
PLATTSBURGH, NY 12901

PRICE QUOTE

Phone 518-561-5400
Fax

HULBERT SUPPLY

Page 1

Printed 12/02/22 KJOB

Quoted

TOWN OF PLATTSBURGH
151 BANKER RD
PLATTSBURGH NY 12901-7307
Tel:518-562-6825 Fax:518-563-8136

Ship To

TOWN OF PLATTSBURGH
151 BANKER RD
PLATTSBURGH NY 12901-7307

Quote #	Quote Date	Exp Date	Customer #	Customer P/O #	Ship Via	Writer
OY12579	11/30/2022	12/30/2022	003179S	WELLMATE	WILL CALL	KJOB
Job ID	Customer Terms			Salesman		
	Net 30 Days			HOUSE ACCOUNTS		
Product	Description	UM	Quant	Unit Price	Extension	
CH33050	WELLMATE WM80 CLASSIC CONNECT FIBERGLASS PUMP TANK (264 GALLON CAPACITY)	EA	1	9453.64	9453.64	
X: _____ (Accepted by)				Sub Total	\$9,453.64	Total
				Freight	\$0.00	
				Misc Charges	\$0.00	
				Tax Amount	\$0.00	
					\$9,453.64	

MESSAGE

SPECIAL ORDERS 50% DEPOSIT & RESTOCKING CHARGE.

TERMS

NO RETURNS WITHOUT SALES RECEIPT. NO RETURNS
AFTER 10 DAYS. ALL ARE SUBJECT TO A RESTOCKING
CHARGE. THE SERVICE CHARGE ON AMOUNTS
OVER 30 DAYS IS 2% PER MONTH OR 24% ANNUALLY.

Barbara Miner

From: Barbara Miner
Sent: Monday, October 31, 2022 10:08 AM
To: Mark Smith
Subject: Water System Pressure Tank Quote

Good Morning Mark –

Is this something you guys carry and can quote? If so can I get a quote and a lead time on shipping?

Thanks,
Barb Miner
Town of Plattsburgh
151 Banker Road
Plattsburgh, NY 12901

Phone: 518-562-6890
barbaram@townofplattsburgh.org

Mark doesn't carry, can't quote.

SERIAL

57252

MODEL WM-80

Well Mate™

WATER SYSTEM
PRESSURE TANK

FOR USE WITH WATER

MAXIMUM OPERATING PRESSURE
MAXIMUM OPERATING TEMPERATURE

125 PSIG
120°F

INSTALLATION INSTRUCTIONS:

1. Shut off power to pump.
2. Shut off house service valve.
3. Connect tank into system.
4. Adjust tank precharge. Precharge must be set at 2 PSIG below the low pressure limit of system.

PRESSURE SWITCH SETTING	PRECHARGE
30 PSIG TO 50 PSIG	28 PSIG
40 PSIG TO 60 PSIG	38 PSIG
50 PSIG TO 70 PSIG	48 PSIG

5. Turn on power to pump, check for leaks. Turn on service valve to house, check operating range. Adjust if necessary.

ATTENTION

THIS UNIT IS DESIGNED TO BE PART OF A PRESSURE SYSTEM MUST CONTAIN A PRESSURE LIMITING DEVICE TO PREVENT OVERPRESSURE OPERATING THE SYSTEM BEYOND ITS DESIGN.

WATER INSTALLATION WHERE FREEZING TEMPERATURES COULD OCCUR UNLESS PROPERLY PROTECTED.

CAUTION: THIS IS A SEALED SYSTEM DO NOT ATTEMPT TO REPAIR OR REPLACE ANY PARTS OR FITTINGS UNDER ANY CIRCUMSTANCES.

DO NOT OPERATE THE FITTING FROM TURNING WASTY WITHIN THE UNIT.

Barbara Miner

From: Chase Baker <cjbaker@rolfeindustries.com>
Sent: Wednesday, November 2, 2022 3:32 PM
To: Barbara Miner
Subject: RE: Water System Pressure Tank Quote

Hi Barbara,

I sent an email on Monday. This isn't anything we handle or have access to --sorry. You can check with FW Webb.

Chase

From: Barbara Miner <barbaram@townofplattsburgh.org>
Sent: Wednesday, November 2, 2022 3:21 PM
To: cjbaker@rolfeindustries.com
Subject: RE: Water System Pressure Tank Quote

*quoted but
not what we
are looking
for.*

Hi Chase --

I was checking back as I haven't heard anything?

Thanks,
Barb Miner
Town of Plattsburgh
151 Banker Road
Plattsburgh, NY 12901

Phone: 518-562-6890
barbaram@townofplattsburgh.org

From: Barbara Miner
Sent: Monday, October 31, 2022 9:57 AM
To: cjbaker@rolfeindustries.com
Subject: Water System Pressure Tank Quote

Good Morning Chase --

Is this something you guys carry and can quote? If so can I get a quote and a lead time on shipping?

Thanks,
Barb Miner
Town of Plattsburgh
151 Banker Road
Plattsburgh, NY 12901

Phone: 518-562-6890
barbaram@townofplattsburgh.org

SERIAL

57232

MODEL WM-80

Well Mate

WATER SYSTEM
PRESSURE TANK

FOR USE WITH WATER

MAXIMUM OPERATING PRESSURE
MAXIMUM OPERATING TEMPERATURE

125 PSIG
120°F

INSTALLATION INSTRUCTIONS:

1. Shut off power to pump.
2. Shut off house service valve.
3. Connect tank into system.
4. Adjust tank precharge. Precharge must be set at 2 PSIG below the low pressure limit of system.

PRESSURE SWITCH SETTING	PRECHARGE
30 PSIG TO 60 PSIG	27 PSIG
40 PSIG TO 60 PSIG	37 PSIG
50 PSIG TO 70 PSIG	47 PSIG

5. Turn on power to pump, check for leaks. Turn on service valve to house, check operating range. Adjust if necessary.

ATTENTION

THIS UNIT IS PRECHARGED TO 22 PSIG AIR PRESSURE. EXCEEDING THIS PRECHARGE PRESSURE MAY CAUSE DAMAGE TO THE TANK. DO NOT EXCEED.

AVOID INSTALLATION WHERE FREEZING TEMPERATURES COULD OCCUR UNLESS PROPERLY PROTECTED.

IF THIS IS A SEALED SYSTEM, DO NOT ATTEMPT TO REMOVE BOTTOM DISCHARGE FITTING UNDER ANY CIRCUMSTANCES.

DO NOT REMOVE BOTTOM FITTING FROM TURNING PIPING INSTALLED ON THIS UNIT.