



## **TOWN OF PLATTSBURGH**

### **WATER AND WASTEWATER DEPARTMENT**

151 BANKER ROAD  
PLATTSBURGH, NEW YORK 12901-7307  
(518) 562-6890  
FAX # (518) 563-8198

*Michael S. Cashman*  
Supervisor

*Charles Kostyk*  
Deputy Supervisor

To: Honorable Michael S. Cashman  
Members of the Town Board

From: Water & Wastewater Department

**RE: Water & Wastewater September Report**

- Collected all required monthly samples.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Review of the monthly Planning Board Meeting regarding upcoming projects.
- There were 133 daily job orders, and 261 locates for DSNY including 4 Emergency.
- There was 2 afterhours callouts.
  1. We responded to a call for a turn off to a residence on Wood Cliff Drive.
  2. We went to turn on a residential service and inspect the repairs on Melody Lane.
- Worked with sewer lining contractor in Cliff Haven.
- The up flow saturator at GPWTP failed and overflowed. We did some troubleshooting and determined a float had failed. We were able to order the replacement parts, but they have not arrived yet. We are manually filling the saturator to be able to continue with fluoridation.
- Three shut off repairs
- Flushing on Cumberland Head.
- MLV repaired on Cumberland Head.
- Located valves for isolating storage tanks off Kimberly Lane.
- Televised culverts for Highway Department.
- Fire flow test on NYS Route 3.
- Two Wastewater Operators to UV Disinfection, O&M and NYSDEC Regulatory Updates training in town.
- Clean manholes in Cadyville.
- Jet sewer main on Graves Lane.
- Cleaned MLV boxes on Cumberland Head.
- Met with contractor doing the pole replacement on the transmission lines in the Moffitt Road area.
- Hydrant repair on Trade Road.
- Restoration on the dump box of the 1-ton.
- Fire extinguisher checks.
- Serviced generators.

- Installed water meter at Bluff Point Lift Station.
- Raised 4 fire hydrants on Rand Hill Road, Tom Miller and Park Row.
- All attended annual Sexual Harassment Training at the Town.
- Locate storm drain manhole for Planning Department. Called in a dig ticket for this area and excavated for a perk test.
- Four (4) Operators attended Asbestos Supervisors Refresher Training Course at Town of Plattsburgh.
- Restoration on truck 41 2016 F150.
- Clean out Cadyville Beach tank for B&G Department.
- Fleet Vehicle Meeting.
- Replaced MLV box Brown Road.
- Installed Fluoride Pump rebuild kit.
- Repaired leak at Akey Road PRV.
- In house and Town wide vehicle and equipment maintenance and repairs.