



TOWN OF PLATTSBURGH

WATER AND WASTEWATER DEPARTMENT

151 BANKER ROAD
PLATTSBURGH, NEW YORK 12901-7307
(518) 562-6890
FAX # (518) 563-8198

Michael S. Cashman
Supervisor

Charles Kostyk
Deputy Supervisor

8 December, 2022

To: Honorable Michael S. Cashman
Members of the Town Board

From: Water & Wastewater Department

RE: Water & Wastewater November Report

- Collected all required monthly samples.
- Meters read, and inventoried. Skip reports completed.
- Operation Reports to CCDH.
- Review of the monthly Planning Board Meeting regarding upcoming projects.
- There were 128 daily job orders, and 133 locates for DSNY including 3 Emergency.
- Annual Inspection with CCDOH.
- There was 5 afterhours callouts.
 1. We responded for an off/on for repairs in Wallace Hill.
 2. There was a callout that ended up being a broken baseplate in Cadyville
 3. There were 3 callouts to open the Town garage to allow the contractors working in Cliff Haven to store their vehicles inside (they were charged for these callouts).
- Replaced the heater at Akey Road PRV
- We installed a new 6" valve for Cumberland Bay State Park.
- Repaired one residential shutoff.
- Installed a meter at NYS Route 9N Lift Station.
- Began efforts on new well house at May Currier Water Treatment Plant. Including digging a ditch for the electrical contractor, installing a gravity drainage line, and prepping and pouring the concrete pad.
- Cleaned up materials and supplies left by the sewer main rehabilitation contractor in front of the pole barn.
- Began accessing the Church Street Lift Station for the installation of the natural gas generator that was removed from I-87 Lift Station.
- New vehicle set up for the 2 new FORD Escapes.
- Pulled and cleaned pumps at CWWTP.
- Pulled and checked the number 2 pump at Sorrell Lift Station. The pump has failed, it was delivered to Emerick Associates for evaluation.
- Replaced rings and cutters on number 1 pump at CWWTP.
- Installed signage at I-87 Lift Station.
- City of Plattsburgh assisted us with their leak detection device at Cadyville Rec Park.

- We found issues with the transfer switch at I-87 Lift Station. There was a glitch with the line power supply, the switch appears to have gotten stuck between line power and auxiliary and had to be manually transferred back to line power. The electrical contractor is investigating.
- Shut down the I-87 Lift Station for 2.5 hours to allow a plumbing contractor to install a new isolation valve for a City of Plattsburgh customer located on Monroe Way.
- Used the Vac truck to make test holes to locate the leak at Cadyville Rec Park.
- In house and town wide vehicle and equipment maintenance and repairs.